

PERMIT APPROVAL SPECIFICATIONS
Sanders County Environmental Health Department
1111 Main St. Thompson Falls, MT, 59873 * 406.827.6909



Owner information:

Mark and Cynthia Holbrook
Name

02 25N 32W
S T R

PO Box 926
Mailing address

11/07/2019
Date Submitted

Spirit Lake, ID 83869
City

11/20/2019
Date Approved

20-067
Permit Number

11/20/2021
Expiration Date

54 Red Fir Lane, Trout Creek
Physical Address

Permit Specifications:

Installation of a gravity wastewater treatment system for a **four (4)** bedroom living unit, an RV dump for occupants of the living unit, and a restroom in a shop/garage for occupants of the living unit.

- 1500-gallon septic tank
- Drainfield per specifications below

Pipe and Gravel

700 square feet
350 lineal feet

4 laterals @ 88 feet

Gravelless Chambers:

595 square feet
298 lineal feet

3 laterals @ 100* feet

or,

4 laterals @ 72* feet

Gravity fed trenches are 2 feet wide and a maximum depth of 36 inches. *Gravelless chamber calculations are based on 2 foot by 4 foot chamber sections. Please follow all Sanders County wastewater regulations & State regulations outlined in Circular DEQ 4, 2013 edition. Install the system as approved on Lot Layout.

Pre-notification is mandatory 48 hours before backfilling system.

A handwritten signature in black ink, appearing to read "M. J. [unclear]", is written over a horizontal line.

Sanders County Sanitarian

Halbrook

S02 T25N R 32W

RECEIVED NOV 12 2019

20 ACRES

663,10

Ledgend

1" = 100'


[H] = House

[E] = Existing 30x30
STRUCTURE NO SEPTIC

W = WELL

[Hatched Box] = Drainfield and
Replacement

X = Soil profile



APPROVED
 DATE 11/19/19 INITIAL M

Tom Wilson