


MISSOULA CITY-COUNTY HEALTH DEPARTMENT  
301 W. Alder 523-4755

INDIVIDUAL SEWER SYSTEM INSPECTION REPORT

Name of Owner Gene Fisher  
Legal Address/Location W 1/2 SW 1/4 SE 1/4 T20 R11 S17 / 4640 Waldb. Hig Road  
Certified Installer Ron Matthew

Type System: New  Replacement   
Septic Tank: Capacity: 1000 gal.  Other  gal., Material: Concrete  Other  , Depth to top: 1 ft. in.  
Drainfield: Total length 300 ft., # of laterals 3 , Trench Depth 20-30 in. to bottom  
Seepage Pit: Height  ft., Depth to Top  ft. in  
Distance of Installation From: Property Lines: 10' Wells: 100' Surface Water: NA Other

Soil Type Fine Sandy loam to Silty Clay Loam PAVED:  YES  NO



Installation Inspected: Approved  Disapproved

Self Inspected By: Ron Matthew Sanitarian 11/14/01 Date  
Corrections Necessary: \_\_\_\_\_

Inspection Witnessed By: \_\_\_\_\_ Date

Deficiencies Corrected: yes  no  Sanitarian \_\_\_\_\_ Date

MISSOULA CITY-COUNTY HEALTH DEPARTMENT  
301 W. ALDER (406)523-4755  
SEWER PERMIT AND APPLICATION

OWNER NAME: Gene Fisher PHONE: 754-5992  
OWNER ADDRESS: 4640 Waldbillig Rd  
CERTIFIED INSTALLER: \_\_\_\_\_  
LOCATION OF INSTALLATION: 1/2 SW 1/4 SE 1/4 T 16 R 16 S 17  
ADDRESS OF SITE: 4640 Waldbillig Road 20  
CERTIFICATE OF SURVEY: # \_\_\_\_\_ SUBDIVISION: Plat A'2  
LOT: \_\_\_\_\_ BLOCK: \_\_\_\_\_ TRACT: \_\_\_\_\_ SIZE OF PARCEL: 20 acres  
GENERAL AREA NAME: London

SEPARATION ADEQUATE FOR:  
(INFO SUPPLIED BY APPLICANT) (CHECK ALL)

Special Conditions and Other Information

	YES	NO
WELLS >100'		
WATER LINES >10'		
FLOODPLAIN >100'		
SURFACE WATER >100'		
HGW >4', >5', >6'		
BEDROCK >6'		
SLOPE <25%		
PROPERTY LINES, BLDGS >10'		

*SANITARY RESTRICTIONS ?	YES	NO
*ANY EXISTING SEPTIC SYSTEMS?	YES	NO
UPGRADE REQUIRED?	YES	NO
*INSIDE OR NEAR FLOODPLAIN:	YES	NO
*PUBLIC SEWER LESS THAN 200 FEET:	YES	NO
*PROPERTY LOCATED IN MWTPSA?	YES	NO
FOR NEW OR INCREASED USE		
___ SUBDIVISION PLAT LANGUAGE EXISTS		
___ DEED RESTRICTION FILED		
*PROPERTY LOCATED IN S.T.E.P. AREA?	YES	NO
___ CITY S.T.E.P. TANK & PERMIT REQUIRED		

SOIL TYPE: Fine Sandy loam to Sandy clay loam  
WATER SUPPLY: Private

TYPE OF SYSTEM TO BE INSTALLED: \_\_\_\_\_ NEW: X REPLACEMENT  
SYSTEM SIZING: X RESIDENTIAL #OF BEDROOMS: 3 GAL/DAY: \_\_\_\_\_  
COMMERCIAL USE \_\_\_\_\_ GAL/DAY: \_\_\_\_\_  
APPLICATION RATE (Gal/day or sq. ft./bedroom): 0.6+  
FROM: PLAT APPROVAL \_\_\_\_\_; SITE EVALUATION TB; ENGINEER \_\_\_\_\_  
SYSTEM SIZE & DESCRIPTION: 1000 Gallons ( X concrete, \_\_\_\_\_ S.T.E.P., \_\_\_\_\_ other) septic tank  
with 300 lineal feet of 24 inch trench drainfield as per site plan attached. Install an 8 inch capped riser from tank to surface.  
S.T.E.P. tanks requires manway and lid to be inspected by the City.

SPECIAL CONDITIONS: \_\_\_\_\_

As purchaser of this permit, I agree to comply with all requirements for installation as described in Missoula City-County Health Code Regulation #1, State Water Quality Bureau Regulations and special conditions described above. This document does not release me from complying with any other State, Federal or Local regulations including but not limited to zoning, building and floodplain regulations.

This permit is valid for twelve (12) months from date of purchase. Sewage disposal systems must be completed within this time and inspected by the Department prior to covering the system. A copy of this permit is to be on site at all times during construction and inspection of the system. Please use the permit number in the upper right hand corner for reference when you call for a final inspection.

Permit purchaser: Gene Fisher Date: 10-25-2001  
Health Authority: Tom Bauger Date: 10/25/01

SEWER PERMIT CHECKLIST

ALL PERMITS:

\*\*\*\*\*

\_\_\_ SITE PLAN ATTACHED TO PERMIT

HOOK-UP TO MUNICIPAL SEWER IS REQUIRED IF: (CHECK ONE)

- \_\_\_ <200' TO PROPERTY LINE IF IN CITY LIMITS CALLED AND REFERRED TO CITY ENGINEERS OFFICE
\_\_\_ <200' TO BUILDING IF OUTSIDE CITY LIMITS DATE
\_\_\_ NOT WITHIN 200 FEET OF MUNICIPAL SEWER PERSON CONTACTED

SPECIAL MANAGEMENT AREAS: (see section XV of Health Code)

- \_\_\_ LINDA VISTA - Connect to public sewer.
\_\_\_ MVTPSA - IF YES, IS DEED RESTRICTION FILED? YES \_\_\_
OR SUBDIVISION PLAT LANGUAGE EXISTS: YES \_\_\_
\_\_\_ RATTLESNAKE - ONE SYSTEM PER LOT - 25' VERTICAL & 100' HORIZONTAL SEPARATION FROM VALLEY
\_\_\_ ROMAN CREEK/TOUCHETTE LANE (W 1/2 SEC 27, S 28, E 1/2 S 29, T 15N, R 21W)
(NORTH OF I-90 AND SOUTH OF FRENCHTOWN CANAL) - CONDITIONS MET \_\_\_

TYPE OF PARCEL: (CHECK ONE)

- \_\_\_ SUBDIVISION FILED PRIOR TO 5/27/61, REQUIRES A SITE EVALUATION. S.E. IN FILE \_\_\_ (YES OR NO)
\_\_\_ SUBDIVISION FILED AFTER 5/27/61 WITHOUT LIFTING, REQUIRES SUBDIVISION REVIEW. S.E. IN FILE \_\_\_
\_\_\_ SUBDIVISION FILED AFTER 5/27/61 WITH RESTRICTIONS LIFTED AND RECORDED
\_\_\_ COS W/LIFTING ON FILE/RECORDED
\_\_\_ COS WITH >20 ACRE EXEMPTION (REQUIRES SITE EVALUATION) SITE EVALUATION ON FILE \_\_\_ (YES OR NO)
\_\_\_ COS WITHOUT LIFTING ON FILE (IS USUALLY AN EXEMPTION FOR WHICH NO PERMIT CAN BE ISSUED I.E.
AG., CEMETERY, etc.)
\_\_\_ TRACTLAND REQUIRES A SITE EVALUATION. (>5 (BEFORE 1973), >10 (BEFORE 1975), >20 ACRES)

NEW PERMITS:

\*\*\*\*\*

PLANNING/ZONING PERMIT REQUIRED (CHECK ONE)

- \_\_\_ INSIDE BUILDING INSPECTOR ZONE - BUILDING PERMIT APPLICATION REQUIRED
\_\_\_ IN ZONED AREA OR IN OR NEAR FLOODPLAIN OR SUBDIVISION FOR LEASE OR RENT - COMPLIANCE PERMIT
REQUIRED.
\_\_\_ OUTSIDE BUILDING INSPECTOR ZONE - NOT IN ZONED AREA OR IN FLOODPLAIN.

SIZE OF PARCEL OR PARCELS: \_\_\_\_\_

- \_\_\_ IF <1/2 ACRE, OWNERSHIPS OF CONTIGUOUS LOTS (prior to May 19, 1988)
DETERMINED FROM ASSESSORS OFFICE. (SEE SECTION V(D)(2))

REPLACEMENT SYSTEMS:


\*\*\*\*\*

HIGH GROUND WATER OR BEDROCK (CHECK ONE)

- \_\_\_ HIGH GROUNDWATER OR BEDROCK AREA - DRAINFIELD, ADSORPTION BED, OR SHALLOW SEEPAGE PIT REQUIRED
\_\_\_ NOT A HIGH GROUND WATER OR BEDROCK AREA


SITE VISIT:(CHECK ONE)

- \_\_\_ SITE VISIT REQUIRED TO VERIFY ROOM FOR:1) DRAINFIELD, ADSORPTION BED OR SEEPAGE PITS
2) GROUNDWATER 3) WELLS 4) ETC.
\_\_\_ SITE VISIT NOT NECESSARY TO VERIFY SOILS, SPACE FOR ADSORPTION AREA, DISTANCE TO WELLS, OR
GROUNDWATER.



4.5 miles all  
the way

N.  
Seely Lake



**This information may not be complete and may contain errors.  
Please consult original records to verify this information.**

**Legal Description** IN W2 SW4 SE4 PLAT A'2 17-20-16 20AC

**Street Address** 4640 WALDBILLIG RD

**Ownership** YATES ANGELA G S

**Mailing Address** PO BOX 904  
CONDON MT 59826

**Suid** 201857

**GeoCode** 299217201090000

**Lot**

**Block** XXX

**Book** 562

**Page** 1297

**Plat** B

**Township** 20

**Range** 16

**Certificate of Survey**