

27-27-20

1. LOT 28 Mayport Harbor 2. .5 A.  
 Legal Description of Property Parcel Size  
 3. Gerald Pryor 4. Same  
 Legal Property Owner Property Occupant  
 5. Bigfork, MT 837-4897 235 Siderius Ln, BF  
 Address & Phone

6. Proposed Dwelling: Conv. Sing. Fam. ; Mob. Home \_\_\_\_\_; Dupl. \_\_\_\_\_; 4-Plex \_\_\_\_\_; Apart. \_\_\_\_\_; Other \_\_\_\_\_  
 7. Existing Structures: None. Other: # 0838700  
 8. Zoning: None.

DENIAL OF PERMIT

If a permit is denied, a hearing before the Board of Health, within 30 days after the receipt of a request shall be granted.

COMMON REASONS FOR DENIAL ARE:

1. Sanitary Restrictions on property (See your deed).
2. Property is not recorded in the courthouse.
3. Insufficient soil separation (four foot separation required between bottom of drainfield trench and groundwater and/or bedrock).
4. Unsuitable soil (criteria is based on site inspection and U.S. Soil Conservation Service Survey).

9. Use Proposed Conforms to Zoning: Yes  No \_\_\_\_\_  
 10. Contractor: self.  
 11. New ; Remodel \_\_\_\_\_; No. of Bedrooms 3  
 12. Septic Tank Size: 900 gallon.  
 13. Water Supply: proposed well  
 14. Soil Type: Silt loam - loamy, fine sand  
 15. Depth of Water Table: 4'0" (test hole)  
 16. Absorption Area: 500 ft<sup>2</sup> (perc tests)  
 17. Describe Drainfield: System was designed by Jay Billmeyer, Marquardt and Assoc. - System shall be installed in accordance with those approved plans - Installation shall be observed by Marquardt and Assoc. To assure compliance with plans

I HEREBY DECLARE the information submitted herein is true, complete and correct to the best of my knowledge. I will install the system according to the FLATHEAD COUNTY REGULATIONS for SUBSURFACE DISPOSAL SYSTEMS and the terms of the permit. I FURTHER AGREE to call and give 24 hours ADVANCED NOTICE for REQUIRED INSPECTIONS of the SYSTEM. PLEASE PHONE 755-5300 Ext. 350!!

\*I have been advised that this permit is ONLY ADVISORY. It establishes THE MINIMUM SIZE FOR THE STANDARDS ADOPTED in Flathead County. The County has not designed my system and I acknowledge that these recommendations do not bind or obligate the County to guarantee this system's operation.

12-28-79  
Date \*

[Signature]  
Signature of Applicant


12/28/79  
Date

Tom Cowan R.S.  
Signature of Authorized Officer Approving Permit Application

\* Permit is void if system is not installed within 90 days of issuance.  
Extension will be granted for 60 days upon request. See Mayport Harbor file for correspondence on lot 28

notify this office at least one day in advance for prompt service.

### LAYOUT



12  
 2 42.5  
 170.0  
 3  
 510

Date 3-27-80 Inspected by Bruce R. S.

Approved [Signature] Disapproved\* \_\_\_\_\_

\*Reason for Disapproval Billmeyer Eng